

AHU supply air+AHU return air: Economy with CC-System		Definition	Outside air	Return air
Station	Bern (Switzerland)			
Height over sea level	m	540.00		
Pressure	hPa	949.65		
Definition: Temp.	°C		20.00	20.00
Definition: Rel. humidity	%		40.00	40.00
Definition: Volume flow humid	m3/h		25000.00	25000.00
Fan: Static pressure without CC-System	Pa		1200.00	900.00
Fan: Efficiency	%		70.00	70.00



Company
Branch
Street
Country

Phone:


Fax:

E-Mail

Homepage


Representative
Direct dialing
xxxxxxxxxx

Software www.zcs.ch

Tube rows on the depth	Service	Temp.-Eff.	Air-Part	Service	Air-Pre.
12.44	---	%	%	h	%
CC-System - Winter 					
	Day 1	70.00	100.00	2000.00	100.00
	Day 2	74.16	50.00	2000.00	25.00
	Day 3	76.02	25.00	380.00	6.25
	Ø Day	72.42	70.66	4380.00	57.62
	Night 1	76.02	25.00	4380.00	6.25
	Night 2	0.00	0.00	0.00	0.00
	Night 3	0.00	0.00	0.00	0.00
	Ø Night	76.02	25.00	4380.00	6.25

Outside air - Supply air		Outside air	Supply air	Outside air	Supply air
Winter - Summer		Winter	Winter	Summer	Summer
Temp.	°C	-18.00	22.00	32.00	16.00
Rel. humidity	%	100.00	40.00	53.30	80.00
Abs. humidity	g/kg	0.81	6.99	17.00	9.66

Return air - Exhaust air		Return air	Exhaust air	Return air	Exhaust air
Winter - Summer		Winter	Winter	Summer	Summer
Temp. (Summer: Return air 26.00 °C)	°C	20.00	0.48	18.78	27.24
Rel. humidity (Summer: Return air 51.40 %)	%	40.00	81.42	100.00	60.00
Abs. humidity (Summer: Return air 11.50 g/l)	g/kg	6.18	3.40	14.50	14.50



Need of energy without		Heater & Humidifier	Cooler	Reheater	Supply air	Return air	Total
Energy recovery		Winter	Summer	Summer	Current	Current	---
SFP (Specific Fan Power < 1500 Recom.)	W/(m3/s)						1001.492
Service / Year	h/a	6623.00	2137.00	1942.00	8760.00	8760.00	8760.00
Max. Capacity	kW	434.58	300.40	27.49	11.90	8.93	---
Need of energy	MWh/a	439.89	129.97	48.04	33.30	24.98	676.18
Energy costs	EUR/MWh	65.00	80.00	60.00	100.00	100.00	70.54
Energy costs	EUR/a	28592.83	10397.87	2882.42	3330.36	2497.77	47701.25

CC-System		Heater	Cooler	Glycol	Supply air	Return air	Total
Energy recovery / Need of energy		Winter	Summer	Current	Current	Current	---
Temp. efficiency / Pump efficiency	%	70.00	63.68	80.00	---	---	---
Return air: Pressure drop	Pa	79.82	79.82	---	---	79.82	---
Supply air: Pressure drop	Pa	67.61	67.61	---	67.61	---	---
Glycol: Volume flow	m3/h	7.97	7.97	7.97	---	---	---
Glycol: Pressure drop	bar	6.00	6.00	6.00	---	---	---
Service / Year	h/a	6533.00	2227.00	8760.00	8760.00	8760.00	8760.00
Max. Capacity	kW	207.94	67.85	1.66	0.67	0.79	---
Energy recovery / Need of energy	MWh/a	247.73	27.63	2.68	1.08	1.28	---
Energy costs	EUR/MWh	60.00	80.00	100.00	100.00	100.00	---
Energy recovery / Energy costs	EUR/a	14864.07	2210.27	267.95	108.25	127.79	---

Need of energy with		Heater & Humidifier	Cooler	Reheater	Supply air	Return air	Total
Energy recovery		Winter	Summer	Summer	Current	Current	---
SFP (Specific Fan Power < 1500 Recom.)	W/(m3/s)						1042.052
Service / Year	h/a	6623.00	2137.00	1942.00	8760.00	8760.00	8760.00
Max. Capacity	kW	226.64	232.54	27.49	12.58	9.72	---
Need of energy	MWh/a	192.16	102.34	48.04	34.39	26.26	403.18
Energy costs	EUR/MWh	65.00	80.00	60.00	100.00	100.00	73.48
Energy costs	EUR/a	12490.09	8187.60	2882.42	3438.61	2625.56	29624.27

AHU supply air+AHU return air: Economy with CC-System



Investment costs

Capital interest	%	1.00
Energy increase	%	1.00
Inflation	%	1.00
Support costs	%	5.00
without CC-System	EUR	75000.00
with CC-System	EUR	126000.00
Additional costs	EUR	51000.00

Overheads

Support costs (+)	EUR/a	2550.00
Energy costs (-)	EUR/a	47701.25
Energy costs (+)	EUR/a	29624.27
Net useful ratio	EUR/a	18076.98

Amortization

BEP (Break even point)	Years	3.31
------------------------	-------	------

Summer

Adiabatic return air cooling	Hours	2227.00
------------------------------	-------	---------

Capital costs

Life cycle	Years	15.00
Investment costs	EUR	126000.00
Energy costs	EUR	29624.27
Support costs	EUR	6300.00
Overheads	EUR	35924.27
Capital costs	EUR	53445.96


Costs	%	EUR
Energy costs without CC-System	92.71	47701.25
Support costs without CC-System	7.29	3750.00
Overheads without CC-System	100.00	51451.25
Energy costs with CC-System	57.58	29624.27
Support costs with CC-System	12.24	6300.00
Overheads with CC-System	69.82	35924.27
Net useful ratio with CC-System	30.18	15526.98

Need of energy	%	MWh
Need of energy without CC-System	100.00	676.18
Need of energy with CC-System	59.63	403.18
Net useful ratio with CC-System	40.37	273.00

CO2 reduction	MWh	t CO2
Energy brown coal (400 kgCO2/MWh)	273.00	109.20
Energy hard coal (330 kgCO2/MWh)	273.00	90.09
Energy heating oil (270 kgCO2/MWh)	273.00	73.71
Energy natural gas (200 kgCO2/MWh)	273.00	54.60

Incomes (EUR)

Expenses (EUR)



Company
Branch
Street
Country
Phone:
Fax:
E-Mail
Homepage

Representative
Direct dialing
xxxxxxxxxx


Software www.zcs.ch

Outside air-Enthalpy (Max. Summer / Min. Winter)

Outside air (°C)

Supply air (°C)

Return air (°C) - (Adiabatic return air cooling = Yes)



Sorbent

Circulation composite systems with efficiencies of 70 % and more were planned and used until 2018 only in German-speaking countries. Other designers apparently don't know the pumps, e.g. Grundfos CRE type, for which pressure drops of 6 bar are no problems. The same "engineers" plan air handling units with air speeds up to 3.5 m/s, no matter how much energy the fans need.



		Glycol pump	Frost conduc.	Total
Need of energy	MWh/a	2.68	60.64	403.18
Need of energy	%	0.66	15.04	100.00
Energy costs	EUR/a	267.95	6064.16	29624.27
Energy costs	%	0.90	20.47	100.00

Factor: Frost conduc. / Glycol pump = 22.63 !!!





Company
Branch
Street
Country

Phone:

Fax:

E-Mail

Homepage


Representative

Direct dialing


xxxxxxxxxx

Software www.zcs.ch


Temp.-Eff. (%)




BEP =Break even point (Years)




Capital costs (EUR)




CC-System (Pa)



Net useful ratio with CC-System (MWh)



Net useful ratio with CC-System (EUR)



Tube rows on the depth	Piece	12.44	14.44	16.44	18.44	20.44	22.44
Temp.-Eff.	%	70.00	73.65	76.61	79.05	81.07	82.77
CC-System - Supply air	Pa	67.61	78.54	89.49	100.44	111.41	122.38
CC-System - Return air	Pa	79.82	93.30	106.87	120.52	134.20	147.91
Additional costs	EUR	51000.00	51000.00	51000.00	51000.00	51000.00	51000.00
Energy costs without CC-System	EUR/a	47701.25	47701.25	47701.25	47701.25	47701.25	47701.25
Energy costs withCC-System	EUR/a	29624.27	29024.64	28597.33	28299.90	28113.53	28000.18
Net useful ratio	EUR/a	18076.98	18676.61	19103.92	19401.35	19587.72	19701.07
BEP (Break even point)	Years	3.31	3.19	3.11	3.05	3.02	3.00
Life cycle	Years	15.00	15.00	15.00	15.00	15.00	15.00
Capital costs	EUR	53445.96	52742.85	52241.79	51893.03	51674.50	51541.59
Net useful ratio with CC-System	%	30.18	31.34	32.17	32.75	33.11	33.33
Net useful ratio with CC-System	EUR	15526.98	16126.61	16553.92	16851.35	17037.72	17151.07
Net useful ratio with CC-System	%	40.37	41.73	42.70	43.38	43.82	44.10
Net useful ratio with CC-System	MWh	273.00	282.16	288.73	293.34	296.29	298.19